

UNDERGROUND STORAGE TANK(S)

SITE NAME:

PTIA- Old Oak Ridge

REGULATED

✓

NONREGULATED

      

YES

NO

RELEASE CONFIRMED:

      

✓

CLEAN-UP INITIATED:

      

      

TANK(S) REMOVED:

✓

      

RELEASE UNDER CONTROL:

      

      

CLEAN-UP COMPLETED:

✓

      

TECHNICIAN:

W. B. G.

DATE:

6/3/93

Old Oak Ridge & Inman Rd.

☒ USGS MAP

☒ BASE MAP

☒ ORIENTATION OF UST

☒ LENGTH OF UST 12'

12'

3'

☒ DIAMETER OF UST 46"

64"

48"

☒ VOLUME OF UST 1K

2K

275

☒ MATERIAL STORED gas

gas

kero

☒ SAMPLE LOCATIONS

8 1/2' DEPTH OF SAMPLE

floor SIDE OR FLOOR SAMPLE

     DEPTH OF TANK BURIAL

backhoe HOW SAMPLE WAS COLLECTED

ice chests SAMPLES PRESERVED AND TRANSPORTED

by lab TOOLS DECONTAMINATED

☒ TIME/DATE SAMPLE COLLECTED

☒ TIME/DATE LAB RECEIVED

☒ LAB RESULTS <10 for all

<10

☒ ANALYSIS METHOD 5030 gas

3550 kero

☒ C.O.C.

5030

☒ REFERENCE TO SAMPLING POINT ON MAP

☒ CORRECT # OF SAMPLES

☒ WITHIN 14 DAYS HOLDING TIME FOR SAMPLES

Safeway TANK DESTINATION

NA DISPOSITION OF SOIL

11.7.91 REMOVAL DATE

☒ COMPLETE GW/UST-2 FORM

heateoil  
6K gas<sup>11/26</sup> also removed, no contamination noted, ∴ no  
samples collected. 11.12.91 removal date  
Tank was located at CFR Station.